



CERTIFICATE OF COMPLIANCE

Certificate No: 1115

This is to certify that
CYMAR CONTRACTING LTD
have installed the under noted materials in accordance with manufacturers instructions and in compliance with BS 8214:2008.

Project Reference/Site Address:

Product	Description of Upgrade Works - Existing Fire Doors
Arrone Grade 13 Hinges	Grade 13 stainless steel fitted to all fire doors
Astroflame Intumescent Hinge Pads	Intumescent hinge pads fitted to all door hinges on fire doors.
Astroflame Lock Sheet 550 x 500 x 0.8mm	Intumescent lock sheets fitted to all sashlocks and hardware on fire doors.
Arrone Fire Door Signage	Fire door signage fitted to all fire doors
Pyroplex Intumescent Smoke Seals	Intumescent smoke seals fitted to door frames/doors where applicable on existing fire door sets.
Norsound Automatic drop seal	Drop down seals fitted to all doors to reduce treshold margins

Date... 28/08/2020

Signed..........

Francis O'Reilly
Contracts Manager

For and on behalf of CYMAR CONTRACTING LTD