



## CERTIFICATE OF COMPLIANCE

Certificate No: 1042

This is to certify that  
**CYMAR CONTRACTING LTD**  
have installed the under noted materials in accordance with manufacturers instructions and in compliance with BS476 1987 Part 20.

Project Reference/Site Address: [REDACTED]

| Product                         | Description of Upgrade Works – Firestopping  |
|---------------------------------|--|
| Safire Intumescent Sealant      | Intumescent sealant applied to tops of compartment walls, around services in apertures and door frames where applicable.   |
| Safire Coated Batt              | Coated batt fitted to tops of compartment walls, into apertures and around services penetrations in compartment walls to risers and sealed with intumescent sealant. |
| Safire Intumescent Pipe Wraps   | Intumescent wraps fitted to pvc pipes penetrating through compartment floors and walls.  |
| Safire Intumescent Pipe Collars | Intumescent collars fitted to pvc pipes penetrating through compartment walls.   |
| Safire Compound                 | Fire rated mortar compound fitted to opes in floor slab.   |
| AIM Fire Barrier                | AIM Fire Barrier fitted to top of compartment walls to provide 60 min fire protection.   |
| Rockwool Fire Barrier           | Double layer of 50 mm fire curtain mechanically fixed to top of compartment walls where applicable to provide 60 min fire protection.                                |

Date 26/11/2019

Signed 

Francis O'Reilly  
Contracts Manager

For and on behalf of CYMAR CONTRACTING LTD